

Vision Power Card Installation Reference



Program version:QBT195101M

U11 Chip Version: 34

Digital Inputs

1	DAMPER 1 FEEDBACK	11	WATER COUNT
2	DAMPER 2 FEEDBACK	12	AUGER FEEDBACK
3	COOL CURTAIN 1 FEEDBACK	13	
4	COOL CURTAIN 2 FEEDBACK	14	
5		15	
6		16	
7		17	RESET PANEL COMM. ALARM
8		18	
9		19	AC POWER ALARM
10		20	SILO A/D WEIGHT

Analog Outputs 0 – 10 Volt

1		4	
2		5	
3		6	

Temperature Sensors


1	TEMPERATURE SENSOR 1
2	TEMPERATURE SENSOR 2
3	TEMPERATURE SENSOR 3
4	TEMPERATURE SENSOR 4
5	
6	
7	OUT TEMPERATURE SENSOR

Fast Analog Inputs


		DIP Switch Position			
		SW1		SW2	
		OFF	ON	OFF	ON
1F	HUMIDITY SENSOR		*	*	
2F	CO2 SENSOR		*	*	
3F		*			*
4F		*			*
5F		*			*
6F		*			*
7F		*			*
8F		*			*

Image 3 main installation

Power Supply



Mother Board to Relay



Communication Lines RS485

